

Ricardo Water Supply Corporation

2024 Consumer Confidence Report

This is your water quality report for January 1 to December 31, 2024

PWS ID Number: TX1370006

Our Drinking Water is Regulated

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. For more information regarding this report contact John Marez at (361) 592-3952.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the RWSC business office at (361) 592-3952.

SPECIAL NOTICE

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

RWSC is a purchased surface water system. Where do we get our drinking water?

Our drinking water is obtained from surface water sources. In past years, the Corporation has used its own groundwater well. In 2008, that well was taken out of service for mechanical reasons. South Texas Water Authority provides the Corporation with treated water from the City of Corpus Christi whose surface water sources are Lake Corpus Christi, Choke Canyon Reservoir, Lake Texana and Colorado River. In emergency situations, the City of Kingsville's groundwater wells can provide water under a pass through agreement. The City of Corpus Christi's water quality data is also included in this report.

Source Water Assessments

TCEQ completed a Source Water Assessment of your water source and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detection of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact John Marez at (361) 592-3952.

Water Loss: In the most recent Water Loss Audit submitted to the Texas Water Development Board for the period of January to December 2020, RWSC lost an estimated 15.6 million gallons of water.

Definitions & Abbreviations

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg – Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

MFL – million fibers per liter (a measure of asbestos)

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

mrem – millirems per year (a measure of radiation absorbed by the body)

na – not applicable.

NTU – Nephelometric Turbidity Units (a measure of turbidity)

pCi/L – picocuries per liter (a measure of radioactivity)

ppb – parts per billion, or micrograms per liter (µg/L) – or one ounce in 7,350,000 gallons of water.

ppm – parts per million, or milligrams per liter (mg/L) – or one ounce in 7,350 gallons of water.

ppq – parts per quadrillion, or picograms per liter (pg/L)

ppt – parts per trillion, or nanograms per liter (ng/L)

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Ricardo Water Supply Corporation 2024 Water Quality Test Results

Ricardo Water Supply Corporation – Lead and Copper

Lead & Copper	Year	MCLG	Action Level (AL)	The 90 th Percentile	# of Sites Over AL	Unit	Violation	Likely Source of Contamination
Copper	2022	1.3	1.3	0.046	0	ppm	N	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead*	2022	0	15	1.6	0	ppb	N	Corrosion of household plumbing systems; erosion of natural deposits.

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Ricardo Water Supply Corporation has developed an inventory of both corporation-owned and customer-owned service lines. To access the inventory, please contact John Marez at 361-592-3952.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	19	7.2 – 29	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	87	42.6 – 159	No goal for the total	80	ppb	Y	By-product of drinking water disinfection.

The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results and TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate (measured as Nitrogen)	2024	1	0.67 – 1.24	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation	Source in Drinking Water
Chloramine	2024	1.16	0.5 – 2.82	4	4	ppm	N	Water additive used to control microbes.

Ricardo Water Supply Corporation – Violations

Total Trihalomethanes (TTHM)

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Violation Type	Violation Begin	Violation End	Violation Explanation
MCL, LRAA	10/01/2024	12/31/2024	Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.

City of Corpus Christi 2024 Water Quality Test Results

City of Corpus Christi – Inorganic Contaminants

Constituent	Year	Highest Single Measurement	Range	MCL (AL)	MCLG	Unit of Measure	Likely Source of Contaminant
Arsenic	2024	2.7	na	10	na	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	2024	0.133	na	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries, erosion of natural deposits.
Chlorite	2024	0.80	0.0 – 0.80	1	0.80	ppm	By-product of drinking water disinfection.
Copper	2024	0.0049	na	(1.3)	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits.
Fluoride	2024	0.35	na	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate	2024	0.15	na	10	10	ppm	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion of natural deposits.
Selenium	2024	4.5	na	50	50	ppb	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Constituent	Year	Highest Single Measurement	Range	MRDL	MRDLG	Unit of Measure	Likely Source of Contaminant
Chlorine Dioxide	2024	490	0 – 490	800	800	ppb	Water additive used to control microbes.
Constituent	Year	Highest Running Annual Average	Range	MCL	MCLG	Unit of Measure	Likely Source of Contaminant
Cyanide*	2024	79*	0 – 130	200	200	ppb	Discharge from steel/metal factories, discharge from plastic and fertilizer factories.
*Calculated as a running annual average: the average of four consecutive quarterly averages, which typically include a portion of the previous year's results.							

City of Corpus Christi – Turbidity

Year/Location	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Entry Point Limit (TT)	Single Measurement Limit (TT)	Likely Source of Contaminant
2024 Plant 1 (NTU)	0.23	100.0	≤0.3	1.0	Soil runoff.
2024 Plant 2 (NTU)	0.24	100.0	≤0.3	1.0	Soil runoff.
Turbidity has no health effects; however, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.					

City of Corpus Christi – Radioactive Contaminants

Constituent	Year	Highest Single Measurement	Range	MCL	MCLG	Unit of Measure	Likely Source of Contaminant
Gross Beta Particle Activity	2023	11	na	50	0	pCi/L	Decay of natural and man-made deposits.
Uranium	2023	1	na	30	0	ppb	Erosion of natural deposits.

City of Corpus Christi – Secondary and Other Constituents Not Associated with Adverse Health Effects


Constituent	Year	Highest Average	Range	MCL	Unit of Measure	Likely Source of Contaminant
Aluminum	2024	0.142	na	0.2	ppm	Abundant naturally occurring element.
Bicarbonate	2024	152	na	na	ppm	Corrosion of carbonate rocks such as limestone.
Calcium	2024	71.3	na	na	ppm	Abundant naturally occurring element.
Chloride	2024	135	na	300	ppm	Abundant naturally occurring element; used in water purification.
Hardness as CaCO ₃	2024	226	na	na	ppm	Naturally occurring calcium and magnesium.
Magnesium	2024	11.7	na	na	ppm	Abundant naturally occurring element.
Manganese	2024	1.4	na	na	ppb	Naturally occurring element.
Nickel	2024	2.8	na	na	ppb	Erosion of natural deposits.
Potassium	2024	10.5	na	na	ppm	Abundant naturally occurring element.
Sodium	2024	110	na	na	ppm	Erosion of natural deposits; oil field by-product.
Sulfate	2024	87	na	300	ppm	Naturally occurring; oil field by-product.
Total Alkalinity	2024	125	na	na	ppm	Naturally occurring soluble mineral salts.
Total Dissolved Solids	2024	516	na	1000	ppm	Total dissolved mineral constituents in water.
Many constituents found in drinking water can cause taste, color and odor problems. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document, but they may affect the appearance and taste of your water.						

Public Participation Opportunity

Date: Monday - Friday
Time: 8:00 a.m. – 5:00 p.m.
Location: South Texas Water Authority
Office: 2302 E. Sage Road, Kingsville, Texas
Phone No: 361-592-3952

En Español – Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (361) 592-3952.

Ricardo Water Supply Corporation



2024 Drinking Water Quality Report